



PRODUCT PERFORMANCE RATING

Document ID 120320201137-14725562

Issued on 3 December 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 00.01.137

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

Product	Air Conditioners / Climatiseurs (AC)
Product type	Comfort air conditioner from 12 to 50 kW/ air-cooled/ multi-split/ reversible
Brand	LG
Range	MU
Product référence	FM49AH.U34/CT24F.NB0x2EA

This performance certificate is delivered for the following project:

Project Name	Company	Project reference	Project location
LG ELECTRONICS	LG ELECTRONICS	LG ELECTRONICS	Italy

FEATURE	VALUE	UNIT
STANDARD COOLING/COOLING PL COND A		
Pc	14.00	kW
Pec	5.60	kW
EER	2.50	



PRODUCT PERFORMANCE RATING

Document ID 120320201137-14725562

Issued on 3 December 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 00.01.137

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
STANDARD HEATING		
Ph	16.00	kW
Peh	4.71	kW
COP	3.40	

FEATURE	VALUE	UNIT
ACOUSTIC		
LwO env	71	dB(A)
Lwl1 env	53	dB(A)

FEATURE	VALUE	UNIT
COOLING PL CONDB		
PcB	10.32	kW
EERB	4.51	



PRODUCT PERFORMANCE RATING

Document ID 120320201137-14725562

Issued on 3 December 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 00.01.137

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
COOLING PL CONDC		
PcC	6.64	kW
EERC	7.65	

FEATURE	VALUE	UNIT
COOLING PL CONDD		
PcD	3.30	kW
EERD	10.95	

FEATURE	VALUE	UNIT
SEASONALCOOLING		
Pdesignc	14.00	kW
SEER	6.00	
ηsc	237.00	%



PRODUCT PERFORMANCE RATING

Document ID 120320201137-14725562

Issued on 3 December 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 00.01.137

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
HEATING PL CONDA		
PhA	8.41	kW
COPA	3.20	

FEATURE	VALUE	UNIT
HEATING PL CONDB		
PhB	5.12	kW
COPB	4.35	

FEATURE	VALUE	UNIT
HEATING PL CONDC		
PhC	3.29	kW
COPC	5.68	

FEATURE	VALUE	UNIT
HEATING PL CONDD		
PhD	3.00	kW
COPD	6.90	



PRODUCT PERFORMANCE RATING

Document ID 120320201137-14725562

Issued on 3 December 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 00.01.137

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
BIVALENT POINT		
Tbiv	-10	°C
COP @ Tbiv	2.61	
Ph TBiv	9.50	kW

FEATURE	VALUE	UNIT
SEASONAL HEATING		
Pdesignh	9.50	kW
SCOP	4.50	
ηsh	177.00	%

FEATURE	VALUE	UNIT
ACOUSTIC IN HEATING		
LwO env in heating	72	dB(A)

FEATURE	VALUE	UNIT
PSBC		
Psbc	22.00	W



PRODUCT PERFORMANCE RATING

Document ID 120320201137-14725562

Issued on 3 December 2020

This product is certified by Eurovent Certita Certification as mentioned on

Certificate N° 00.01.137

This document is valid at the date of issue - **Check the current validity on www.eurovent-certification.com**

FEATURE	VALUE	UNIT
PSBH		
Psbh	22.00	W

FEATURE	VALUE	UNIT
GENERAL		
Capacity Control	Variable	
Main Power Supply	400-3-50	
Refrigerant	R410A	
Refr. Line	5	m
Mounting	Cassette	
No. of IU	2	